



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1396821 (LR 68691)

Master Contract: 154155

Project: 1555410

Date Issued: 2004/07/20

Issued to: Westlock Controls Corporation
280 Midland Avenue
Saddle Brook, New Jersey 07662
USA
Attention: Mr. Anthony Paolini

The products listed below are eligible to bear the CSA Mark shown



Issued by: Ron Wildish

Authorized by: Nick Alfano, Operations
Manager

PRODUCTS

CLASS 3218 02 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary
Devices-For Hazardous Locations

Class I, Div 2, Groups A, B, C & D; Class II, Div 2, Groups F & G; Class III; Enclosure Type 4X:

Network Valve Monitors, Model 7244, input rated 24 Vdc, 120 mA; Model 7344, input rated 9-32 Vdc, 24 mA;
Model 7444, input rated 24 Vdc, 120 mA; Model 7544, input rated 24 Vdc, 120 mA; Model 7644, input rated
24 Vdc, 60 mA & Model 7744, input rated 50 mA ; -20C to +60C Ambient, Temperature Code T4.

Network Valve Monitors, AVID Series, Model ZRP, input rated 24 Vdc, 120 mA; Model ZRF, input rated 9-32
Vdc, 24 mA; Model ZRM, input rated 24 Vdc, 120 mA; Model ZRD, input rated 24 Vdc, 60 mA & Model
ZRA, input rated 50 mA; -20C to +60C Ambient, Temperature Code T4.



CSA INTERNATIONAL

Certificate: 1396821 (LR 68691)

Master Contract: 154155

Project: 1555410

Date Issued: 2004/07/20

Class I, Div 1, Groups C & D; Class II, Div 1, Groups E, F & G; Class III; Enclosure Type 4X;

Class I, Div 2, Groups A, B, C & D:

Network Valve Monitors, Model 7279, input rated 24 Vdc, 120 mA; Model 7379, input rated 9-32 Vdc, 24 mA; Model 7479, input rated 24 Vdc, 120 mA; Model 7579, input rated 24 Vdc, 120 mA; Model 7679, input rated 24 Vdc, 60 mA & Model 7779, input rated 50 mA; -20C to +60C Ambient, Temperature Code T4.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 14-95 - Industrial Control Equipment

CSA Std C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

CSA Std C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures

CSA Std C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

CEC Part 1, Section 18 for reference.



CSA INTERNATIONAL

Supplement to Certificate of Compliance

Certificate: 1396821

Master Contract: 154155

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1555410	2004/07/20	Update of Report 1396821 to Include Explosion-Proof Versions (7x79 Series) and to add Div. 2 versions, Models 7444, 7544 and ZRM.

History

Original Certification - Models 7244, 7344, 7644, 7744, ZRP, ZRF, ZRD & ZRA Network Valve Monitors.