



WYMV.E100737

Telemetering Equipment for Use in Hazardous Locations

See General Information for Telemetering Equipment for Use in Hazardous Locations

WESTLOCK CONTROLS CORP
280 MIDLAND AVE
SADDLE BROOK, NJ 07662 USA

E100737

Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G.

Valve position indicators, Models 9880, E9880.

Class I, Groups A, B, C and D; Class II, Groups E, F and G.

Valve position monitors, Accutrak, Model 360 followed by M2, M4, M6 or M8, may be followed by E2; Models CS, RS.

Class I, Groups C and D; Class II Groups F and G.

Valve position monitor, Model E360 followed by M2, M4, M6 or M8, may be followed by E2; Models CS, RS for use in hazardous locations.

Class I, Groups B, C and D; Class II, Groups E, F and G; Class I, Division 2, Group A.

Valve position monitors, Module 3, Model No. 3479. Mini Mod 3, Models 3079, EM-300-E6, EPIC.

Class I, Groups B, C and D; Class II, Groups E, F and G.

Valve position indicators, Models 9881, E9881.

Class I, Groups C and D; Class II, Groups E, F and G.

Valve position monitors, Accutrak, Series 2000, 4000, Models 2007X, 4040; Eliminator, Series 3000, 4000, Models 3030, 3057, 4080, E3479, 5050, 5080; Series 9000, Model E9479; Quantum, Model 749 may be followed by M2, M4 or M6; Mini Mod 3, Model E3079; Accutrak, Model E360 followed by M2, M4, M6 or M8, may be followed by E2; Models CS, RS.

Class I, Groups C and D; Class II, Groups E, F and G; Class I, Division 2, Groups A and B.

Valve position monitors, Model 2217X; Quantum, Model 749M; Series 9000, Model 9479; Spectrum, Model 9479-DT; Models CS, RS.

Last Updated on 2002-01-15

This page and all contents are Copyright © 2005 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2005 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

