



WYMV7.E100737

Telemetering Equipment For Use In Hazardous Locations, Certified For Canada

See General Information for Telemetering Equipment For Use In Hazardous Locations, Certified For Canada

WESTLOCK CONTROLS CORP
280 MIDLAND AVE
SADDLE BROOK, NJ 07662 USA

E100737

Class I, Groups A, B, C and D, Division 2; Class II, Groups F and G, Division 2. Valve position indicators, Models 9880 , E9881 .

Class I, Groups C and D; Class II, Groups F and G. Valve position indicators, Accutrak Model E360 followed by M2, M4, M6 or M8, may be followed by E2 ; Models CS , RS .

Class I, Groups A, B, C and D; Class II, Groups F and G. Valve position indicators, Accutrak Model 360 followed by M2, M6, M8 or M44, may be followed by E2 ; Models CS , RS .

Class I, Groups C and D; Class II, Groups E, F and G. Valve position monitors, Mini Mod 3 Model E3079 , Module 3, Model E3479 .

Class I, Groups B, C and D; Class II, Groups E, F and G; Class I, Group A, Division 2. Valve position monitors, Mini Mod 3 Models 3079 , Module 3, Model 3479 , EM-300-E6 , EPIC .

Class I, Groups C and D; Class II, Groups F and G; Class I, Division 2, Groups A and B. Spectrum, Models 9479-DT , CS , RS .

Last Updated on 1998-04-11

This page and all contents are Copyright © 2005 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material.

In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2005 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

