



Certificate of Compliance

Certificate: 1607903

Master Contract: 154155

Project: 2484263

Date Issued: November 22, 2012

Issued to: Westlock Controls Corporation

280 North Midland Ave
Saddle Brook, NJ 07663
USA

Attention: Anthony Paolini

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Eshwar Kashyap

Issued by: Eshwar Kashyap

PRODUCTS

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -
Certified to US Standards

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Ex nA IIC T4 Gc:

Class I, Zone 2; AEx nA IIC T4 Gc:

Class I, Division 2, Groups A, B, C, D; Class II, Division 1, Groups E, F, G; Class III; Type 4X; IP 67:

DEPIC, Model D410 and D420 Non-Contact Position Transmitter. Supply 10-30 Vdc, 4-20mA; Temp. Code T4; Ambient - 50 Deg. C to + 85 Deg. C.

DEPIC, Model F410 and F420 Non-Contact Position Transmitter; supply 9-32 Vdc, 25mA; Temp. Code T4; Ambient - 50 Deg. C to + 85 Deg. C.



Certificate: 1607903

Master Contract: 154155

Project: 2484263

Date Issued: November 22, 2012

Ex d IIB+H2 T5 Gb:

Class I, Zone 1; AEx d IIB+H2 T5 Gb:

Class I, Division 1, Groups B, C, D; Class II, Division 1, Groups E, F, G; Class III; Type 4X; IP 67:

DEPIC Model D410 and D420 Non-Contact Position Transmitter, supply 10-30 Vdc, 4-20mA; Temp. Code T5;
Ambient - 50 Deg. C to + 85 Deg. C.

DEPIC, Model F410 and F420 Non-Contact Position Transmitter; supply 9-32 Vdc, 25mA; Temp. Code T4;
Ambient - 50 Deg. C to + 85 Deg. C.



Certificate: 1607903

Master Contract: 154155

Project: 2484263

Date Issued: November 22, 2012

APPLICABLE REQUIREMENTS

C22.2 No. 0-10	General Requirements – Canadian Electrical Code, Part II
C22.2 No. 25-1966	Enclosures for Use in Class II, Groups E, F and G Hazardous Locations
C22.2 No. 30-M1986	Explosion-Proof Enclosures for Use in Class I Hazardous Locations
CAN/CSA-C22.2 No. 94-M91	Special Purpose Enclosures
C22.2 No. 142-M1987	Process Control Equipment
C22.2 No. 213-M1987	Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
CAN/CSA-C22.2 No. 60079-0:11	Explosive Atmospheres - Part 0: Equipment - General requirements
CAN/CSA-C22.2 No. 60079-1:11	Explosive Atmospheres – Part 1: Equipment protection by flameproof enclosures "d"
CAN/CSA-C22.2 No. 60529:05	Degrees of protection provided by enclosures (IP Code)
UL 50 (11th Ed.)	Enclosures for Electrical Equipment
UL 916 (4th Ed.)	Energy Management Equipment
UL 1203 (4th Ed.)	Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations
UL 1604 (3rd Ed.)	Electrical Equipment for Use in Class I and II, Division 2; Class III Hazardous (Classified) Locations
ANSI/ISA 12.12.01-2007	Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
ANSI/UL 60079-0:09	Electrical Apparatus for Explosive Gas Atmospheres - Part 0: General Requirements
ANSI/UL 60079-1:09	Electrical Apparatus for Explosive Gas Atmospheres - Part 1: Flameproof Enclosures "d"
ANSI/IEC 60529:2004	Degrees of Protection Provided by Enclosures (IP Code)
CAN/CSA C22.2 No. 60079-15:12	Electrical apparatus for explosive gas atmospheres - Part 15: Construction, test and marking of type of protection "n" electrical apparatus
ANSI/UL-60079-15:2009	Electrical Apparatus for Explosive Gas Atmospheres – Part 15: Type of Protection "n"