



Member of the FM Global Group

FM Approvals  
1151 Boston-Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781 762 9375 www.fmapprovals.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

**PHARMA 2 Models 99P2, 76P2 & 77P2.**

NI/II/2/ABCD/ T4;  $-10^{\circ}\text{C} \leq T_a \leq +60^{\circ}\text{C}$ ;

DIP/II/2/FG/T4;  $-10^{\circ}\text{C} \leq T_a \leq +60^{\circ}\text{C}$ ;

IP55

*Special Conditions of Use:*

1. Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application, including a tool removable cover.

### Equipment Ratings:

Valve Monitor Pharma 2 Models 99P2, 76P2 and 77P2 is suitable for Class I, Division 2, Groups A, B, C, D; Dust IgnitionProof Class II, III, Division 2, Groups F, and G with an ambient of  $-10^{\circ}\text{C} \leq T_a \leq +60^{\circ}\text{C}$  and an IP55 enclosure

### FM Approved for:

Tyco  
280 Midland Avenue, Saddle Brook NJ



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

C22.2 No 157	1992
C22.2 No. 213	1987
C22.2 No 142	1990
CAN/CSA-E60079-0	2002
CAN/CSA-E60079-15	2002
C22.2 No. 1010.1	2004
IEC 60529	1989


Original Project ID: 3033224

Approval Granted: February 19, 2009

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC



J.E. Marquedant  
Group Manager, Electrical



Date