Certificate of Compliance

Certificate: 2599677 (LR 81057-1) **Master Contract:** 154155

Project: 2599677 **Date Issued:** April 15, 2013

Issued to: **Westlock Controls Corporation**

280 North Midland Ave
Saddle Brook, NJ 07663
USA
Attention: Mr. Anthony Paolini

The products listed below are eligible to bear the CSA Mark shown

T. Munteanu

Issued by: T. Munteanu, P.Eng.

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Limit switch, Cat No 2004 rated 15A, 125/250V ac max, 6A, 24V dc in special purpose CSA Type 4/4X enclosure.

Limit switch, Cat No 9044 rated 3A, 120V ac, 2A, 24V dc, in special purpose CSA Type 4/4X enclosure.

Limit switches, Cat No 5004M8 and 5004M12 rated 0.1A, 24V dc max, in special purpose CSA Type 4 enclosure.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14 - Industrial Control Equipment

CAN/CSA-C22.2 No. 94 - Special Purpose Enclosures